



STANDARD 19: BALCONY RAILING PANELING

JANUARY 1989

APRIL 1996, RESOLUTION M3-96-28

REVISED JANUARY 2007, RESOLUTION 03-07-01

REVISED APRIL 2011, RESOLUTION 03-11-50

GENERAL REQUIREMENTS REVISED APRIL 2011, RESOLUTION 03-11-49

GENERAL REQUIREMENTS REVISED JANUARY 2018, RESOLUTION 03-18-12

REVISED MAY 2018, RESOLUTION 03-18-56

1.0 GENERAL REQUIREMENTS

See Standard Section 1: General Requirements

2.0 APPLICATIONS

- 2.1** All balcony railing panels shall be attached directly to the railing. No panels shall be attached to the building, deck, or flooring.
- 2.2** Paneling height may be up to the top railing and extend no further than the bottom of the railing. Paneling shall not extend to the balcony deck. Paneling must cover the railing completely from side to side, and shall not extend beyond any existing railing.
- 2.3** All paneling shall be rigid and easily removable.
- 2.4** Paneling may be of white vinyl lattice only as manufactured by Veranda[®] or Dimensions[®]; existing attached metal panels that are painted to match the color of the wall to which the railing is attached may remain.
- 2.5** Paneling shall be attached to the inside portion of handrails.