



STANDARD 26: SKYLIGHT INSTALLATIONS

AUGUST 1992

REVISED MAY 2003, RESOLUTION 03-03-43

GENERAL REQUIREMENTS REVISED APRIL 2011, RESOLUTION 03-11-49

GENERAL REQUIREMENTS REVISED JANUARY 2018, RESOLUTION 03-18-12

REVISED JUNE 2018, RESOLUTION 03-18-92

1.0 GENERAL REQUIREMENTS

SEE STANDARD SECTION 1: GENERAL REQUIREMENTS

2.0 APPLICATIONS

- 2.1** Skylights may be of openable or fixed type.
- 2.2** Interior finish, such as open well or luminous panel ceiling, is optional. Size of opening at ceiling line is optional unless specifically called out on Standard Plan drawing to be of a special size, to comply with light and ventilation requirement.
- 2.3** Skylight(s) installed in any roof, under warranty with the Mutual's reroofing contractor, shall be sealed using the same specifications in force at that time.
- 2.4** Roofing must be in strict conformance with the I.B.C., Third Mutual Standards, and standard drawings.
- 2.5** Electrical fixtures may be placed inside skylight wells providing they meet the latest edition of the N.E.C.
- 2.6** Skylights shall be in keeping with the architecture of the building and be either off-white or smoke tinted in color. Approval by the Alterations Department office will be deemed in keeping with the existing architecture. All skylights shall match other existing skylights. Clear skylights are not acceptable on any roof.

- 2.7** One skylight shall be permitted per 10 linear feet of a patio cover's longest dimension, and all skylight placement and spacing shall be approved by the Permits and Inspections office.
- 2.8** Maximum skylight size shall not exceed International Building Code and Title 24 requirements. All non-standard skylights are to be reviewed by the Mutual's Board of Directors.
- 2.9** Skylights shall be curb mounted and installed per Standard Plans and/or drawings in detail, size and location. Skylights will meet or exceed all current International Building Code (I.B.C.), State and/or City Standards.
- 2.10** Skylights shall be mounted on minimum 2"x6" curbs. Mounting shall be with Galvanized or equal hex-head screws to aid in removal during reroofing.
- 2.11** No skylight shall be installed within 12" of any vent, ridge, or vertical structure.
- 2.12** Skylights installed in existing acoustical sprayed ceilings may encounter asbestos. The resident(s) and contractor(s) must meet or exceed requirements of Federal, State or local government regarding asbestos removal procedures.
- 2.13** All skylights shall be of ICBO approved double lens construction.
- 2.14** Square-Flex™ or equivalent skylight tubes are permitted, provided that the installation meets all of the aforementioned standards.
- 2.15** **No trusses shall be cut in the installation of skylights.**