



STANDARD 27: SOFT WATER UNITS

MAY 1996

GENERAL REQUIREMENTS REVISED JUNE 2011, RESOLUTION 01-11-104
GENERAL REQUIREMENTS REVISED JANUARY 2016, RESOLUTION 01-16-08
REVISED DECEMBER 2019, RESOLUTION 01-19-102

1.0 GENERAL REQUIREMENTS

SEE STANDARD SECTION 1: GENERAL REQUIREMENTS

2.0 INSTALLATIONS

- 2.1** All installations require approval by the Permits and Inspections Office prior to commencing the work.
- 2.2** Tanks may be located in a garage, water heater cabinet, or outside of unit as approved by the Permits and Inspections Office.
- 2.3** Exposed exterior installations must be enclosed in a 5/8" CDX plywood cabinet, textured (to match exterior wall) or paneled and painted to match the color of the building. All exposed plumbing shall be painted color of surface to which attached.
- 2.4** Pipe runs shall be kept to a minimum.
- 2.5** Isolation valves for emergency shut-off will be required.
- 2.6** Soft water units shall be connected directly to the service line of the manor owner/owners' name that appears on the permit.
- 2.7** No regenerative-type softeners will be allowed as per all applicable laws.
- 2.8** Approval of landscape installation to conceal the soft water unit cabinets will be required.